



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

Please Note: The school is following recommended remediation to help reduce children's exposure to lead in drinking water.

School District: FederalWay

School Name: Seqouyah Middle school

School Code: 5029

School Address: 3425 South 360th street, Auburn Washington 98001

Number of Samples Collected: 27

Date Collected: 12/19/2019

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31534	FirstDraw	other	Kitchen sprayer	3	12/26/2019	High pressure
31535	other	other		<1	12/26/2019	
31536	FirstDraw	Tap	Left tap tripple sink	2	12/26/2019	
31537	FirstDraw	Tap	Tap near oven	2	12/26/2019	
31538	FirstDraw	Tap	Tap near buffet server	2	12/26/2019	
31539	FirstDraw	Bubbler	Upper left outside boys bathroom	<1	12/26/2019	
31540	FirstDraw	Bubbler	Lower right outside girls bathroom	<1	12/26/2019	
31941	FirstDraw	Bubbler	Outside boys bathroom lower right	<1	12/26/2019	
31942	FirstDraw	Bubbler	Outside hirls bathroom upper left 1st floor	<1	12/26/2019	
31943	FirstDraw	Bubbler	Upper left girls bathroom orange wall	<1	12/26/2019	
31944	FirstDraw	Bubbler	Loer right boys bathroom orange wall	<1	12/26/2019	
31945	FirstDraw	Bubbler	2nd floor outside boys bathroom upper left	<1	12/26/2019	
31946	FirstDraw	Bubbler	2nd floor outside girls restroom lower right	<1	12/26/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31947	FirstDraw	Bubbler	2nd floor outside boys bathroom lower right	<1	12/26/2019	
31948	FirstDraw	Bubbler	2nd floor outside girls bathroom upper left green	<1	12/26/2019	
31949	FirstDraw	Bubbler	2nd floor outside boths bathroom lower left orange wall	<1	12/26/2019	
31950	FirstDraw	Bubbler	2nd floor outside girls bathrpom upper right orange wall	<1	12/26/2019	
31951	FirstDraw	Bubbler	Single left bubbler gym	<1	12/26/2019	
31952	FirstDraw	Bubbler	Right bubbler wall	<1	12/26/2019	
31953	other	BottleFiller	Left water bottle filler	<1	12/26/2019	Sample considered flush. Both fixture work at the same time.
31954	FirstDraw	Bubbler	Boys locker left	<1	12/26/2019	
31955	FirstDraw	Bubbler	Boys locker right	1	12/26/2019	
31956	FirstDraw	Bubbler	Girls locker left	<1	12/26/2019	
31957	FirstDraw	Bubbler	Girls locker	<1	12/26/2019	
31958	FirstDraw	Tap	Music room	1	12/26/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31959	FirstDraw	Tap	Ochestra room	1	12/26/2019	
31960	FirstDraw	Tap	Nurses station	1	12/26/2019	